

# SGS



## CERTIFICATE NCS/FI 24189 A2

Our Ref. 251364-1

**Product** Membrane gland  
**Type** VET 5-35  
**Trade mark** MAR-CON  
**Certificate Holder/  
Manufacturer** Trelleborg Industrial Products Finland Oy  
Kikkerlöntie 72  
FI-38300 SASTAMALA, FINLAND  
**Technical information** IP67  
**Other information** See the Appendix to this certificate  
**The product is certified  
according to the following  
standard(s)** SFS 4698:2006

**Validity** This certificate is valid until 31 December 2012 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

**Directive information** The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.

**Date of issue** 15 March 2011

**Signature** **SGS Fimko Ltd**

Sixten Lökfors  
Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at [www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm). Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Ltd.

Särkiniementie 3 P.O.Box 30 FI-00211 Helsinki, Finland  
t. +358 9 696 361 f. +358 9 692 5474 [www.fi.sgs.com](http://www.fi.sgs.com)

Business ID 0978538-5 Member of the SGS Group (SGS SA) security printing ltd switzerland

Additional information

Type VET 5-7:	Grey or black EPDM- or CR- rubber for cables diameter 5-7 mm for hole 16 mm and thickness of the wall 1-4 mm
Type VET 7-10:	Grey or black EPDM- or CR- rubber for cables diameter 5-10 mm for hole 19 mm and thickness of the wall 1-4 mm
Type VET 8-12:	Grey or black EPDM- or CR- rubber for cables diameter 8-12 mm for hole 23 mm and thickness of the wall 1-4 mm
Type VET 10-14:	Grey or black EPDM- or CR- rubber for cables diameter 10-14 mm for hole 23 mm and thickness of the wall 1-4 mm
Type VET 14-20:	Grey or black EPDM- or CR- rubber for cables diameter 14-20 mm for hole 29 mm and thickness of the wall 1-4 mm
Type VET 20-26:	Grey or black EPDM- or CR- rubber for cables diameter 20-26 mm for hole 38 mm and thickness of the wall 1-4 mm
Type VET 26-35:	Grey or black EPDM- or CR- rubber for cables diameter 26-35 mm for hole 48 mm and thickness of the wall 1-4 mm

This certificate replaces previously issued certificate 24189 A1, dated 21 December 2009, due to reissued certificate.



Supplement to Certificate: NCS/FI 24189 A2

Internal ref.  
Sixten Lökfors

15 March 2011

## NORDIC CERTIFICATION SERVICE

We hereby confirm that the product(s) appearing from the certificate with above certificate reference also comply(ies) with requirements for secondary certification in the following countries: Denmark, Norway, Sweden

### NOTIFICATION

<b>Certificate holder for Denmark, Norway, Sweden</b>	Trelleborg Industrial Products Finland Oy Kikkerlöntie 72 FI-38300 SASTAMALA, FINLAND Please send the invoice and the certificate directly to certificate holder, Attn: Ms. Niina Posti, mailto: <a href="mailto:niina.posti@trelleborg.com">niina.posti@trelleborg.com</a>
<b>Safety standard(s) applied</b>	SFS 4698:2006
<b>EMKO TS document(s) considered</b>	Not applicable
<b>EMC requirements</b>	-
<b>The assignment is based on</b>	Testing in own premises from SGS Fimko Ltd.
<b>Limitations or reservations regarding the testing / examination performed</b>	None
<b>Certification marks</b>	Affixing of the certification mark(s) of the Nordic body(ies) on the product must not take place before notice about national certification is received from the individual body.
<b>Production surveillance</b>	Will be carried out by SGS Fimko according to agreed procedures.
<b>Other information</b>	When certificate is applied for in Norway (NEMKO), Denmark (DEMKO) and Sweden (SEMKO) a copy of this certificate and the enclosed material shall be attached to the application.
<b>Test samples must be submitted to the secondary body(ies)</b>	No
<b>Date of issue</b>	15 March 2011

This Notification may be challenged if it is more than 3 years old.

**SGS Fimko Ltd**

Signature

Sixten Lökfors  
Project Manager